



Tout le rotomoulage

I, the undersigned Mr. Yannick JUHÈRE, President of the Company:

*Ateliers Polyvalents de Châteauneuf SAS
Zone Artisanale DOSLET
F 35430 CHATEAUNEUF D'ILLE ET VILAINE*

Declares that the septic tanks Millennium Standard, Reinforced and Super Reinforced, ranging from 3 to 15m³, used for the treatment of domestic wastewater to population for up to 50 PTE and produced by this company, are in accordance with the requirements of Annex ZA of Standard EN 12566-1/A1.

The initial type testing has been carried out by the notified body 1476.

Volume tests Compliant

Watertight Testing Compliant

Test Pit Test Compliant

Hydraulic efficiency (lamellar prefilter PF17) ≤ 1.73 g of micro beads

Made in Chalonnes sur Loire,
August, 19th, 2010.